

TEST REPORT

Test Report Issued To:

KP DECORATORS

.1/528, DHATIGARA STREET, KHARVAWAD, NANPURA ,
SURAT, GUJARAT, INDIA, 395001,

Test Report No: D200715021/D200715021-10

Date of Issue: 23-Jul-2020



Sample Booking/Receipt Date: 15-Jul-2020

Date of Start of Testing: 21-Jul-2020

Date of Completion of Test: 22-Jul-2020

Customer Relationship Number 60096

Sample Description :

GLASS FIBER REINFORCED GYPSUM CEILING SHEET



Customer Reference No :

Kind Attention : MR. RAJESH K MISTRY

E-Mail: kpdecorators9@gmail.com

Contact No: 9825125213

Sample Condition : GOOD

Sample Quantity (Approx) : -

Sample Size (Approx) : -

SAMPLE NOT DRAWN BY OUR LABORATORY. THE RESULTS RELATE ONLY TO THE ITEMS TESTED

Report Issued by

Authenticity of report can be verified by mail at verification@spectrolab.in

This is a Digitally Signed Report and hence doesn't require Physical Signature.

Spectro Analytical Labs Limited S-1, GNEPIP, Surajpur Industrial Area,Phase-V, Kasna, Greater Noida-201308 (India)

Phone : +91-120-2341252,2341251 || URL : www.spectro.in || Email: care@spectro.in

BIS & DDA Approved, ISO 9001:2015, ISO 14001:2015 & ISO 45001:2018 Certified Laboratory


Please refer to our Website <http://www.spectro.in/spectro-policies.html> for Terms & Condition

JOB ID : D200715021-1

TEST REPORT FOR RATE OF BURNING

Specimen Size : 100×12.5 mm

Conditioning: The specimen conditioned at a relative humidity of 65±5% and a temperature of 27±2°C for 24 hours.



<u>Test Parameter</u>	<u>Requirement</u> (As per IS 5509-2000)	<u>Observed Result</u>	<u>Acceptance</u>
Rate of Burning (Thickness of specimen: 13 mm Approx)	Time taken for mass loss 30-70% should not be less than 20 minutes.	Time taken for mass loss was more than 20 minutes	Confirmed

Remark -The submitted sample meets the requirement as per IS: 5509-2000 w.r.t above test.

- Result relates only to the behaviour of specimen tested.

Test Method- IS 1734 (P-3) - 1983

-- End of Test Report --

Analyst Signature



Authorised Signatory